



"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	<p>DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025</p> <p>भारतीय मानक ब्यूरो BUREAU OF INDIAN STANDARDS 15 / ISO 9001 GMS</p> <p>Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015</p>	 एक कदम स्वच्छता की ओर
--	--	--

### BACTERIOLOGICAL ANALYSIS REPORT

Dated: 24.11.2025

No. DJB/DTQC/ CWA (W&S)III /ACWA (south)/ Bact/P.S./2025-2026/252-260/19.11.2025


Bacteriological Analysis Report as per IS 10500:2012


To M/S - Deepalaya School  Kalkaji Extn.  New Delhi -110019	Party Ref.No./Date: DSKE/ADMIN/2025/1114/30.10.2025 Dept. Challan No. /date: 74/10.11.2025 Dt.of sample collection: 19.11.2025 No. of Sample: Nine (09) Collected by: Name- Sh. Nagendra Ojha Desig. - Lab/Tech.
--	---


S.No	Particulars	Clarity	Residual chlorine	Total Coliform Count/ 100 ml sample
1	DJB Supply Inlet Near Gate No- 1	Clear	1.25	ND
2	Drinking Point Near Room No- 113, Ground Floor	Clear	Nil	ND
3	Drinking Point Near Medical Room, Ground Floor	Clear	Nil	ND
4	Drinking Point Near Class-III- B Room No-213,1 <sup>st</sup> Floor	Clear	Nil	ND
5	Drinking Point Near Class-V-A Room No-309,2 <sup>nd</sup> Floor	Clear	Nil	ND
6	Drinking Point Near Class-IV-A Room No-302,2 <sup>nd</sup> Floor	Clear	Nil	ND
7	Drinking Point Near Class-III- A Room No-10,lower ground Floor	Clear	Nil	ND
8	Drinking Point Near Canteen	Clear	Nil	ND
9	Drinking Point Near Class-UKG Gate No.-2	Clear	0.25	ND

\*ND- Not Detected

RESULT: -Collected water samples as mentioned above at S.No. 1 to 9 were found BACTERIOLOGICALLY SATISFACTORY.

  
ACWA (SOUTH ZONE)  
Dr. D. P. SINGH  
ACWA (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi


  
BACTERIOLOGIST (SOUTH ZONE)  
MANESHWAR DIXIT  
BACTERIOLOGIST (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

  
24.11.25  
DEEPA  
ASST. SC/BACT  
DEEPALAYA SCHOOL  
A-14, Kalkaji Extn., New Delhi  
MANAGER  
DEEPALAYA SCHOOL  
A-14, Kalkaji Extn., New Delhi-110019



Delhi Jal Board

DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015

A.C.W.A.(South)/Paid/2025-26/141-145/Challan No.74 Dated 10.11.2025

Serial No.8212

Date-22.11.2025

Deepalaya School

Block A-14, Kalkaji Ext.

New Delhi-110019

Date of sample collection : 19.11.2025

S.No	Characteristics	Unit	Acceptable Limit	DJB Supply Gate I	Drinking Point Room Near No 113 GF	Drinking Point near Medical Room GF	Drinking Point near III A GF	Drinking Point near Canteen
1.	Clarity	Unit	5	Clear	Clear	Clear	Clear	Clear
2.	Odour	---	Agreeable	No. Obj.	No. Obj.	No. Obj.	No. Obj.	No. Obj.
3.	pH Value	---	6.5-8.5	7.6	7.2	7.6	7.3	7.3
4.	Turbidity	NTU	1	2.53	0.85	0.50	0.61	0.77
5.	Conductivity	µmho/cm <sup>2</sup>	---	268	148	154	222	86
6.	Total Dissolved Solids	mg/L	500	174	96	100	144	56
7.	Phenolphthalein Alkalinity	mg/L	---	NIL	NIL	NIL	NIL	NIL
8.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	200	88	62	64	78	34
9.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	200	158	90	94	118	46
10.	Carbonate hardness	mg/L	---	88	62	64	78	34
11.	Non-Carbonate Hardness	mg/L	---	70	28	30	40	12
12.	Calcium Hardness	mg/L	---	92	48	50	66	26
13.	Magnesium Hardness	mg/L	---	66	42	34	52	20
14.	Chloride (as Cl)	mg/L	250	12	12	12	12	08
15.	Ammonia (as Total N)	mg/L	0.5	ND	ND	ND	ND	ND
16.	Nitrite (as N)	mg/L	---	ND	ND	ND	ND	ND
17.	Nitrate	Mg/L	45	4.7	1.4	1.5	3.9	1.0
18.	Sulphate (as SO <sub>4</sub> )	mg/L	200	38	26	28	30	12
19.	Fluoride	mg/L	1.0	0.42	0.20	0.22	0.38	0.16
20.	Iron	Mg/l	0.3	0.06	0.04	0.04	0.04	0.02
21.	Calcium (as Ca)	mg/L	75	36.8	19.2	20.0	26.4	10.4
22.	Magnesium (as Mg)	mg/L	30	15.84	10.08	8.16	12.48	4.80
23.	Free Residual Chlorine	mg/L	0.2	1.25	0.25	Nil	Nil	Nil

*[Signature]*  
22/11/25  
ACWA(SOUTH)

*[Signature]*  
CHEMIST

*[Signature]*  
22/11/25  
A/CHEMIST

Dr. D. P. SINGH  
ACWA (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

*[Signature]*  
Manager

**MANAGER**  
DEEPALAYA SCHOOL  
Deepalaya School  
A-14, Kalkaji Ext., New Delhi-19  
New Delhi-110019






DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



A.C.W.A.(South)/Paid/2025-26/145-146/Challan No.74 Dated 10.11.2025 Serial No.8212 Date-22.11.2025

Deepalaya School  
Block A-14, Kalkaji Ext.  
New Delhi-110019

Date of ample collection : 19.11.2025

S.No	Characteristics	Unit	Acceptable Limit	Drinking Point near UKG	Drinking Point near III B Ist F Room No 213	Drinking Point near Class 5 A Room No 309	Drinking Point near class 4 A Room No 302
1.	Clarity	Unit	5	Clear	Clear	Clear	Clear
2.	Odour	---	Agreeable	No. Obj.	No. Obj.	No. Obj.	No. Obj.
3.	pH Value	---	6.5-8.5	6.6	7.2	7.3	7.4
4.	Turbidity	NTU	1	0.95	0.94	1.07	0.82
5.	Conductivity	µmho/cm <sup>2</sup>	---	30	166	258	258
6.	Total Dissolved Solids	mg/L	500	20	108	168	168
7.	Phenolphthalein Alkalinity	mg/L	----	NIL	NIL	NIL	NIL
8.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	200	16	68	84	82
9.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	200	34	96	156	156
10.	Carbonate hardness	mg/L	----	16	68	84	82
11.	Non- Carbonate Hardness	mg/L	----	18	28	72	74
12.	Calcium Hardness	mg/L	----	10	54	88	84
13.	Magnesium Hardness	mg/L	----	24	42	68	72
14.	Chloride (as Cl)	mg/L	250	06	12	12	12
15.	Ammonia (as Total N)	mg/L	0.5	ND	ND	ND	ND
16.	Nitrite (as N)	mg/L	----	ND	ND	ND	ND
17.	Nitrate	Mg/L	45	0.8	1.9	3.9	4.0
18.	Sulphate (as SO <sub>4</sub> )	mg/L	200	08	25	36	34
19.	Fluoride	mg/L	1.0	0.12	0.28	0.43	0.41
20.	Iron	Mg/l	0.3	0.02	0.04	0.04	0.04
21.	Calcium (as Ca)	mg/L	75	4.0	21.6	35.2	33.6
22.	Magnesium (as Mg)	mg/L	30	5.76	10.08	16.32	17.28
23.	Free Residual Chlorine	mg/L	0.2	0.25	0.25	Nil	Nil

*[Signature]*  
ACWA(SOUTH)

*[Signature]*  
CHEMIST

*[Signature]*  
22/11/25  
A/CHEMIST

Dr. D. P. SINGH  
ACWA (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

*[Signature]*  
Leela Y. Jind

*[Signature]*

MANAGER  
DEEPALAYA SCHOOL  
A-14, Kalkaji Ext.  
New Delhi-110019



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, CENTRAL ZONE  
SHIV MANDIR MARG, LAJPAT NAGAR, NEW DELHI

No.DHO/CNZ/2025/D 37

Dated: 07/04/2025

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no DHO/CNZ/2023/D-1238 dated 14.12.2023. The school premises were re- inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: M/s Deepalaya School .

Address of School: -14, Kalkaji Extn. New Delhi-110019.

Shifts: ONE Timing: MORNING


No. of Students: Boys:683 Girls:1034 Total:- 1717

No. of Staff (Teachers): Female: 58 Male: 26 Total: 84

That the accommodation provided for the class rooms as calculated.

- (A) On floor space is sufficient Yes  
(B) On Cubic space is sufficient Yes
- That the classrooms are well ventilated Yes
- That the classrooms are kept neat and clean Yes
- That the classrooms are well lighted Yes
- That the building is not in substantial repair in the class of NIL
- That the drinking water is wholesome Wholesome
- That the latrines arrangement is adequate and there are sufficient latrines.
- That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.

  
2/4/25

Dy. Health Officer  
Central Zone

Deputy Health Officer  
Central Zone, MCD



Manager  
DEEPA LAYA SCHOOL  
19

